

This report shows all the responses to the Fire Risk Assessment survey, including raised tasks.

Asset ID: 33666 **Blk1 1-5 16 Manor House St & 18 Manor House St, Peterborough**

Cover Sheet

Photo



Date of Fire Risk Assessment	31 Oct 2022
Date of Next Fire Risk Assessment	31 Oct 2025
FRA Frequency (Months)	36
Purpose of Fire Risk Assessment	3 year Re-Assessment
Type of Fire Risk Assessment	Type 3 (Common Parts and Flats - Non Destructive)
Fire & Safety Assessor	Lynn betteridge

This report has been validated by:

Name: *Paul McMillan - Fire & Safety Manager*

Date: 31/10/2022

Comment: Suitable & Sufficient

The Scheme

Scheme Name	Manor House
Scheme Address	Blk1 1-5 16 Manor House St & 18 Manor House St, Peterborough
Postcode	PE1 2TQ
Region	East
Scheme Manager	
Scheme Tel. No	
Scheme Inspection Completed	Yes
Enforcing Fire Authority	Cambridgeshire fire service
Other staff in attendance	None
Number of on-site Accent staff	None
Number of other (non-Accent) staff	

The Building

Accommodation Type	General Needs (S30)
Build Date	Jan 11 2018
Number Of Homes	6
Homes breakdown	Flat
External wall construction	Facing Brick
External wall finish	Facing Brick
Roof construction	Timber
Roof covering	Flat Roof, Slate Pitched
PEEPs in place where necessary	No
Current Evacuation Strategy	Stay Put (Delayed) Evacuation
Conversion or purpose-built	Conversion
Number of storeys	2
Number of floors on which car parking is provided	0
Is there a habitable basement?	No
Number of internal Staircases (protected or unprotected?)	1
Number of External Staircases	1
External Balcony part of escape route?	N/A
Unusual features	None
Building Access Conditions for Fire Brigade	Vehicular Access to one or more elevations

Asset ID: 33666

Blk1 1-5 16 Manor House St & 18 Manor House St, Peterborough

Fire Detection and Warning System	Flats and common areas linked
Grade of fire alarm	
Category of fire alarm	LD3 Minimum Protection
Emergency Lighting Provision	Non Maintained System - Common Areas
Portable Fire Extinguishers supplied/fitted	No,
Fixed Fire Fighting Installations	No,

Customers

Number of occupants	10
Occupant tenure type breakdown	General Needs, Leasehold

Fire Safety Related Customer Safety Servicing

Overdue communal gas safety checks	0
Overdue domestic gas safety checks	0
Overdue communal electrical condition checks	0
Overdue domestic electrical condition checks	0
Overdue alarm call pull chord tests	0
Overdue communal PAT testing	0
Overdue customer mobility scooter PAT testing	0
Overdue Monthly Emergency Lighting Switch Tests	1
Overdue Annual Emergency Lighting tests	1
Overdue Weekly Fire Alarm Testing	0
Overdue Fire Panel - Six Monthly Testing	0
Overdue Fire Safety Equipment tests	0

Building Fire Safety Surveys - Communal Doors

Failing Communal Fire Doors	0
Communal Fire doors due for replacement within 5 years	0

Dwelling Doors

Failing Dwelling Fire Doors	0
Dwelling Fire doors due for replacement within 5 years	0

Fire Risk Assessment Survey Results

Scheme and Building Information

Photo



Date of Fire Risk Assessment	31/10/2022
FRA Frequency (Months)	36
Purpose of Fire Risk Assessment	3 year Re-Assessment
Type of Risk Assessment	Type 3 (Common Parts and Flats - Non Destructive)
Quantity	1
Fire & Safety Assessor	Lynn betteridge
Enforcing Fire Authority	Cambridgeshire fire service
Scheme Tel. No	
Other staff in attendance	None
Number of on-site Accent staff	None
Number of other (non-Accent) staff	
Scheme Inspection completed	Yes
Number of occupants	10
Personal Emergency Evacuation Plans in place	No
Current Evacuation Strategy	Stay Put (Delayed) Evacuation
Conversion or purpose-built	Conversion
Number of Storeys	2
Number of floors on which car parking is provided	0
Is there a habitable basement?	No
No. of internal staircases (protected/unprotected)	1
Number of external staircases	1
External balcony part of escape route?	N/A
Unusual features	None

Fire Risk Assessment Survey Results

Building access conditions for Fire Brigade	Vehicular Access to one or more elevations
Surroundings: Residential/Commercial	
Fire Detection and Warning System	Flats and common areas linked
Grade of Fire Alarm	
Category of Fire Alarm	LD3 Minimum Protection
Emergency Lighting Provision	Non Maintained System - Common Areas
Portable Fire Extinguishers / Fire Blankets supplied / fitted	No
Water Extinguisher(s) present	No
Foam Extinguisher(s) present	No
Dry Powder Extinguisher(s) present	No
Carbon Dioxide Extinguisher(s) present	No
Fire Blanket(s) present	No
Fixed Fire Fighting Installations supplied / fitted	No
Dry Riser(s) present	No
Wet Riser(s) present	No
Sprinkler System present	No
Hosereel(s) present	No
Automatic Opening Vent(s) present	Yes

Electrical Sources of Ignition

Electrical installation within common areas in good condition and no obvious damage?	Yes
Comment	The electrical installation within the communal areas is satisfactory last recorded is 30th of the 5th 2022
Valid Electrical Installation Condition Reports held on file? (Common Areas & General Needs Flats)	Yes
Comment	
Electrical App/PA Testing - tested within past 12 months?	N/A
Comment	
Absence of trailing leads and adapters?	Yes
Comment	
Evidence that mobility scooters are not being stored/charged in common areas?	No
Comment	
Is there a purpose built mobility scooter store/charging area?	No

Comment

Does the building have a lightning protection system?

Yes

Comment

Is the protection system adequately maintained?

N/A

Comment

Gas installations

Is there a commercial/domestic gas supply to the scheme?

No

Comment

Storage heaters

Other Sources of Ignition

Is there a no smoking policy in place, which is enforced and adhered to?

Yes

Comment

Adequate security against arson?

Yes

Comment

Are refuse/recycling bin areas managed and suitably located?

Yes

Comment

Are there communal cooking facilities at this scheme?

No

Comment

Housekeeping

Are all electrical/intake/service cupboards secure and free from general waste, contractors waste and residents personal items?

Yes

Comment

The electrical service cupboards on location under the main staircase a fire door 30-minute is fitted with a door lock to prevent unauthorised access

Are unnecessary accumulations of combustible materials or waste avoided?

Yes

Comment

Are combustible materials and substances separated from ignition sources and stored appropriately?

N/A

Comment

Furniture/furnishings in good condition, fire retardant/resistant and comply with modern standards and regulations?

Yes

Comment

Other Significant Fire Hazards

Are all other significant fire hazards adequately controlled? Yes

Comment

Means of Escape from Fire

Is it considered that the building is provided with reasonable means of escape in case of fire? Yes

Comment

A single staircase which is within the converted building adequately allowance for means of escape in case of Fire

Escape routes unobstructed and safe to use? Yes

Comment

Exits immediately openable without a key and/or failsafe's function correctly? Yes

Comment

Reasonable distances of travel where there is a single/alternative direction of travel? Yes

Comment

Escape routes lead to final exits and open in direction of escape where necessary? Yes

Comment

All fire exit doors open into communal staircase exit ground and first floor there are 3 fire doors separating the flats from the communal area

Fire Spread and Development

Is it considered that the compartmentation is of a reasonable standard? Yes

Comment

When the conversion of the building took place compartmentation was checked and completed to the current standard at the time

Is there reasonable limitation of surface finishes that might promote fire spread (walls, floors, ceilings)? Yes

Comment

Are fire dampers/shutters provided in ducts/refuse chutes to protect means of escape against fire, smoke and combustion products? Yes

Comment

An aov is fitted on the second floor to help with smoke and combustion products being released to the atmosphere keeping the stairwell clear for residents to exit and fire service to enter

As far as can be reasonably ascertained, is the compartmentation within roof spaces of a satisfactory standard? Yes

Comment

Loft hatches fire resisting? N/A

Comment	None in communal area.
As far as can be reasonably ascertained, is the fire stopping above cross corridor fire doors within suspended ceiling void of a satisfactory standard?	N/A
Comment	
Do external walls, doors, windows and anything attached to the exterior, limit fire spread?	Yes
Comment	The external walls doors and windows will not propagate fire spread around the envelope for the building
If Smoke Control Systems (AOV's) are fitted, are the records of annual testing available?	Yes
Comment	
Are roller shutter doors that are required to be FR, fire resisting and self-closing?	N/A
Comment	

Emergency Escape Lighting

Is the emergency lighting correctly specified and installed as per current standards?	Yes
Comment	
Emergency lighting units in good condition and securely fixed to walls/ceilings?	Yes
Comment	
Records of monthly/annual testing available?	Yes
Comment	The monthly emergency lighting test was carried out on the 26th of September 22 and the annual emergency light drop test was carried out on the 5th of August 22

Fire Safety Signs and Notices

Are the correct Fire Action/Advice notices displayed in prominent locations within the common areas?	Yes
Comment	
Directional fire escape signage in place and adequate?	Yes
Comment	
Is there suitable LIFT signage i.e. do not use in case of fire?	N/A
Comment	
Do common area fire doors display the correct signage on both sides where applicable?	Yes
Comment	

Means of giving Warning in case of Fire

Is the scheme fitted with a communal area fire alarm?	Yes
Comment	
Is fire detection and warning system appropriate for occupancy and fire risk, as per BS 5839-1:2017?	Yes
Comment	
Is the fire detection and warning system maintained/tested and all certificates saved on file?	Yes
Comment	Tunstall the fire contractor carried out stand-alone detector tests on the 24th of the 11th 2017 and recorded on activate
Fire alarm components in good condition and securely fixed to walls/ceilings?	Yes
Comment	
Hold open devices operate at the sounding of the alarm and are in a serviceable condition?	N/A
Comment	
Are there heat detectors located in the Kitchen, Boiler, Plant Room and Laundry?	N/A
Comment	
Is the fire alarm panel remotely monitored, and if so are there records of regular testing?	N/A
Comment	

Fire Extinguishing Equipment

Is fire extinguishing equipment and/or fixed fire fighting installations provided at this scheme?	N/A
Comment	
Portable fire extinguishers - appropriate type/number/position?	N/A
Comment	
Correct signage displayed by each fire extinguisher?	N/A
Comment	
Fire blanket in communal kitchen, secured to the wall, complete with signage?	N/A
Comment	
Dry risers - Inlet/outlet boxes secured and/or securing straps fitted to outlet valves?	N/A
Comment	
Records available of fire fighting equipment servicing within past 12 months?	N/A

Comment

Management of Fire Safety

Are these premises regulated by the Building Safety Regulator under the Building Safety Act? Yes

Comment

Will this FRA be shared with all Accountable Persons for the premises? Yes

Comment

How will this sharing be achieved? Communication

Are there other Responsible Persons who share or have fire safety duties in respect of the premises? Yes

Have all details required by regulations been shared with all other Responsible Persons? Yes

Comment Yes fire authority.

Have all details required by regulations to be shared with us from other Responsible Persons been received and recorded? Yes

Comment

Will this FRA be shared with all other Responsible Persons for the premises? Yes

Comment

How will this sharing be achieved? Communicated

Is an office or IL scheme being inspected? No

Comment

Passenger Lift

Is the scheme fitted with a passenger lift? N/A

Comment

Is the lift in full working order at the time of the FRA? N/A

Comment

Is the lift fitted with a firefighters switch? N/A

Comment

Servicing and insurance inspection - Evidence of regular servicing/maintenance? N/A

Comment

Premises Inspection Box

Is there a premises information box for fire & rescue service use? No

Comment

Evacuation Policy

Are there suitable arrangements for summoning the fire service?

Yes

Comment

Residents responsibility.

Taking FRA findings, is the evacuation policy appropriate for the scheme as per latest guidance?

Yes

Comment

Engagement with Residents

Has information of fire procedures been disseminated to residents?

Yes

Comment

Is general fire safety information disseminated to residents?

Yes

Comment

FRA Frequency

Taking the findings of this assessment into account, is the frequency of the FRA correct?

Yes

Comment

Miscellaneous

Are there any other observations/actions to raise that are not covered above.

No

Are there fire related remedial works required at this property, that will affect the fabric of the building?

No

Comment

Were there any unsatisfactory aspects of the Fire Risk Assessment? (Visible on Building Safety Report).

No

Risk Calculator - Fire

The following risk estimator is based on the general health and safety risk level estimator contained within BS 8800: 1996. Guide to occupational health and safety management systems.

1. Taking into account the fire prevention measures observed at the time of this risk assessment, it is considered that the hazard from the fire (the probability of ignition) at this building is:

LOW MEDIUM HIGH

2. Taking into account the nature of the building, the occupants, the fire protection afforded and any procedural arrangements observed at the time of the assessment, it is considered that the consequences for life safety in the event of a fire would be:

MINOR MAJOR CRITICAL

The definition of the above terms is as follows:

FRA Review Frequency

MINOR	Outbreak of fire is unlikely to result in serious injury or death of any occupant (other than the occupant sleeping in a bedroom in which a fire occurs).
MAJOR	An outbreak of fire could result in injury of one or more occupants, but is unlikely to lead to fatalities.
CRITICAL	There is significant potential for serious injury or death of one or more occupants.

3. The above estimates are then read into the following matrix table to give the overall risk level for the site:

Fire Hazard	Minor	Major	Critical
Low	Trivial	Tolerable	Moderate
Medium	Tolerable	Moderate	Substantial
High	Moderate	Substantial	Intolerable

When the level of risk is established, the action level can be read from the table below:

Risk Level	Guide to actions and appropriate timescales
Trivial	No action is required
Moderate	Efforts should be made to reduce the risk level and this should be carried out within the specified time periods.
Substantial	Considerable resources may have to be allocated to reduce the risk level. It may be necessary to limit the occupation of some parts until urgent remedial action is taken.
Intolerable	The building (or the relevant area) should not be occupied until the risk is reduced.

The Overall Risk Level for this asset is: **Trivial**